



Certificate of Conformity

Certificate No.: 1988AP1108N005002
Equipment: Grid-Connected PV inverter

Brand Name:  **GOODWE**
YOUR SOLAR ENGINE
Test Model No.: GW3648D-ES, GW5048D-ES

Applicant: Jiangsu GoodWe Power Supply Technology Co.,Ltd.
No.90 ZiJin Rd., New District, Suzhou,215011,China

Report No.: PVSP191108N005-1

Use in accordance with regulations:

The previously listed inverters are three-phase and have an automatic disconnection / connection device controlled by software, in accordance with the regulations stated below. The end user will not have access to the adjustment software.

Applied rules and standards

UNE 206006 IN:2011

Island operation detection tests of multiple photovoltaic inverters connected to a parallel network

UNE 206007-1 IN:2013

Requirements for connection to the electricity network Part 1: Inverters for connection to the distribution network

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage network



Name: James Huang
Technical Manager/ New Energy Team
Date: 2020-04-30

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.