

JIANGSU GOODWE POWER SUPPLY
TECHNOLOGY CO., LTD.
Mr. Jiang Tao

Date : 04.09.2020
Our ref. : CSC 01
Your ref.: Jiang Tao

No.90 Zijin Rd.,
New District, Suzhou
215011 Jiangsu
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Hybrid Inverter
Model Designation : See Certificate
Certificate No. : AK 50479561 0001
Report No. : 60408633 001

Dear Mr. Jiang Tao,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Weichun Li

CC: JIANGSU GOODWE POWER SUPPLY

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E
of Conformity



Registration No.: AK 50479561 0001

Report No.: 60408633 001

Holder: **JIANGSU GOODWE POWER SUPPLY
TECHNOLOGY CO., LTD.**
No.90 Zijin Rd.,
New District, Suzhou
215011 Jiangsu
P.R. China

Product: PV-Inverter
Hybrid Inverter

Identification: Type Designation: GW5048D-ES GW3648D-ES
Serial Number : Engineering Samples
Firmware Version: 1818C
Remark : The reference standard of VFR 2019,
Enedis-FOR-RES_18E: 2019, SEI REF 04 V7/
Category 3 and EDT V1 were considered,
refer to test report 60408633 001 for
details.

Tested acc. to: UTE C15-712-1/07.13
DIN V VDE V 0126-1-1:2006+A1

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 04.09.2020




Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg