



Certificate of Conformity

Certificate No.: 2088AP0603N027016
Product: Grid-tied Photovoltaic Inverter
Brand Name:  **GOODWE**
YOUR SOLAR ENGINE
Test Model No.: GW4K-DT, GW5K-DT, GW6K-DT, GW8K-DT, GW10KT-DT,
GW12KT-DT, GW15KT-DT
Applicant: **JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD**
No.90 ZiJin Rd., New District, Suzhou,215011,China
Report No.: PV200603N027-R1

Use in accordance with regulations:

Automatic disconnection device with three-phases mains surveillance in accordance with EN 50549-1:2019 for photovoltaic systems with a three-phases parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards

EN 50549-1:2019, ČSN EN 50549-1:2019

Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network - Generating plants up to and including Type B

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

EN 50438:2013, ČSN EN 50438:2014, PPDS Příloha 4:2018

Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.



Name: James Huang
Technical Manager/ New Energy Team
Date: 2021-01-28

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.